

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-0085:166

Page 1 of 1

CATEGORY: Control Units (Household)

LISTEE: ADT Security Sytems, 4128 North Freeway Blvd, Sacramento, CA 95834
Contact: Ron Dalton (310) 725-2972 Fax (310) 725-2942*

DESIGN: Model 487267 The basic system consists of Model 487267 central processing unit, and Model 487269 touchpad. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as household control units for use with a 6v 3.2 AH sealed lead acid battery and the following devices: Interactive Technologies Model 60-506 smoke detector (7272-1126:109) ESL Model 445AT smoke detector (7272-0447:104) Interactive Technologies Model 60-278 siren (7135-1126:107) Interactive Technologies Model 13-046 siren (7135- 1126: 107) Interactive Technologies Model 60-353 siren (7135-1126:107)

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

NOTE: Burglary and other non-fire functions were not examined. Connection to sensors located within the electric company's power meter is a supplementary function and has not been examined.

XLf: 7167-1126:106

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager